



Livingston County Drain Commissioners Office

2300 East Grand River Avenue, Suite 105, Howell, MI 48843-7581

Phone: 517-546-0040 / Fax: 517-545-9658

SUSPENSION OF TREATMENT CHARGES INSPECTION FORM

Site Inspection for LIVINGSTON REGIONAL SANITARY SEWER Connection with GRINDER PUMP

Date _____ Applicant: _____

Address: _____

Parcel ID Tax Code No: _____

Caution, the request to suspend service prevents water removal. Sewer backflow is stopped at the street but the County is not liable for incidental water that may accumulate in the residence. The property owner is responsible for all damages onsite while service is disconnected. If damage requires replacement of any equipment, all parts and labor to restore service are property owner expenses. An escrow sufficient to cover 120% of the estimated costs and inspection fees shall be established at the Office of the Drain Commissioner when restoration of service is requested. Upon completion of the repairs and inspection, the remaining escrow shall be remitted to the property owner

- THE GRINDER PUMP # _____ HAS BEEN REMOVED
- THE GRINDER PUMP WET WELL (CAN) AND LID HAS BEEN INSPECTED, PHOTOGRAPHED AND FOUND TO BE WITHOUT DAMAGE OR CRACKS
- THE POWER CORD FROM THE CONTROL PANEL AT THE BUILDING TO THE GRINDER PUMP MUST BE REPLACED? YES NO
- THE CONTROL PANEL IS INTACT AND FUNCTIONING? YES NO
- THE CONTROL PANEL MUST BE REPLACED? YES NO
- THE CONTROL CIRCUIT FOR THE PUMP SHALL BE ON A DEDICATED CIRCUIT (20 AMP MINIMUM)
- CONTROL PANEL MUST BE INSTALLED AT LEAST 5' ABOVE FINISHED GRADE AND IN VIEW OF THE TANK
- THE CURB STOP VALVE AND/OR CHECK VALVE MUST BE REPLACED?
CURB STOP VALVE YES NO CHECK VALVE YES NO

COMMENTS and ADDITIONAL EXPENSE(S): _____

Inspected by _____ Property Owner _____
signature signature